

RCV BY:VA DEPT OF HEALTH

:10- 5-92 : 3:33PM :

7042837885-

OFFICE ENV HEALTH:# 2

SENT BY:CHARLOTTE PIPE

: 8-28-92 :11:07AM :

DEPARTMENT-

7042837885:# 2

CHARLOTTE

PIPE AND FOUNDRY COMPANY

P.O. Box 38420 • Telephone 704/372-8030

CHARLOTTE, NORTH CAROLINA 28233

JULY 22, 1992

Mr. Kurment Chapman
Ferguson Enterprises
4716 Harrison Road
Fredricksburg, VA 22401


Dear Kurment:

Following up on our telephone conversation concerning the use of primer/cleaner on PVC-DWV foam core pipe.

The use of primer/cleaner on PVC-DWV foam core pipe when used in accordance with ASTM D-2855 and in accordance with the primer/cleaner manufacturer recommendations will not have adverse effect on PVC-DWV foam core pipe.

If we can be of any further assistance to you please feel free to call upon me.

Sincerely,



Alan Biggers
Senior Vice President

AB/tw